Government of West Bengal
Office of the Assistant Engineer
R.W.S. Purulia Sub-Division, P.H.E. Dte.
Ranchi Road: Purulia Pin:-723101
E-mail :- ae_pur_rws@wbphed.gov.in

CERTIFICATE

This is to certificate that the water supplied by Oxford International School, P.O-Dulmi-Nadiha, Purulia-723102 has been tested for 10 parameters, as specified in attach Test Report dated 24.09.2026, by the Purulia District water Testing Laboratory.

As per the test result, all the 10 parameters examined are found to be within the permissible limits prescribed for drinking water, in the absence of an alternative source of water.

06/10/26

Assistant Engineer
R.W.S. Purulia Sub-Division,
P. H. Engineering Dte.

Assistant Engineer
RWS Purulia Sub-Division
P.H.E. Dte.
Govt. of W.B.

PURULIA DISTRICT WATER TESTING LABORATORY
Under
PURULIA DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE
GOVT. OF WEST BENGAL

TEST REPORT

Date of Collection: 23.09.2026	**Brought By : Staff**
Place of sample- OXFORD INTERNATIONAL SCHOOL, Tata Road(NH-32), P.O.-Dulmi-Nadiha,Dist-Purulia,Pin-723102(W.B).India	
Quantity: 1000ml	**Mode of packing: PP Bottle**
Analysis started on: 23.09.2026	**Analysis Completed : 24.09.2026**
Type of Sample : Boaring	**Location: OXFORD INTERNATIONAL SCHOOL**

SL. NO.	PARAMETER	UNIT	RECOMMENDED DRINKING WATER QUALITY as per IS: 10500-2012		Test Result
			Desirable Limit	Permissible Limit (Max.)	
A.	Physical and Chemical results				
1.	PH		6.5-8.5	No relaxation	7.23
2.	Total Hardness, as $CaCO_3$	Mg/l	200	600	207.31
3.	Iron. As Fe, max	Mg/l	0.3	1.00	0.03
4.	Fluoride , max	Mg/l	1.00	1.5	0.62
5.	Turbidity	NTU	1	5	1.86
6.	Mn	Mg/l	0.1	0.3	0.01
7.	TDS	Mg/l	500	2000	350
8.	Chloride	Mg/l	250	1000	143.18
B.	Bacteriological results				
1.	Total Coli form Bacteria	CFU/100 ml	Absent	Absent	Absent
2.	Feacal coli form	CFU/100 ml	Absent	Absent	Absent

Note- All the above parameters are under permissible limit.

PURULIA DISTRICT WATER TESTING LABORATORY PHED Govt. of West Bengal

SIGNATURE
CHEMIST/BACTERIOLOGIST
District Water Testing Laboratory

SIGNATURE
24/09/26.
CHEMIST/BACTERIOLOGIST
District Water Testing Laboratory
PURULIA DISTRICT WATER TESTING LABORATORY PHED
Govt. of West Bengal